

***Small Drinking Water Treatment
Technologies for Compliance with
the Enhanced Surface Water
Treatment Rules***

**Craig Patterson, Roy Haught, Jim Goodrich,
Steve Allgeier*, Dan Schmelling*, and Tom Sorg**

USEPA, ORD, Water Supply and Water Resources Division
USEPA, OW, OGWDW, Standards and Risk Management Division*

Rajib Sinha and Lee Heckman

Shaw Environmental, Inc.
Cincinnati, Ohio

Region 9 Product Expo

February 8, 2005

Today's Presentation

- Small Systems Overview
- Bag/Cartridge Filter Background
- Bag/Cartridge Filter Studies
- Bag Filter Field Studies
- LT1 and LT2 ESWTR Overview
- Arsenic Demonstration Program
- Future Small Systems Research

Small Systems Overview

3

160,000 Small Community and Non-Community Drinking Water Systems

- 50,000 Community
- 110,000 Non-Community Systems
- Account for 68 million people
- Serving transient and non-transient populations of 10,000 people or less

Small Systems Overview

Small Systems (FY2003) contribute to:

- 94% of the Safe Drinking Water Act Amendment violations
- Health-Based Violations
 - 77% Maximum Contaminant Level
 - 23% Treatment Technique

EPA remains focused on improving small system compliance

U.S. EPA Test & Evaluation Facility




- **EPA's Small Systems Research Center**

Small Systems Research U.S. EPA T&E Facility

6

Current Drinking Water Research

- Filtration
- Disinfection
- Advanced Oxidation
- Point-of-Use
- Water Reuse
- Remote Telemetry
- Distribution Systems
- International Collaborations



Further Information

Upload “Small Drinking Water Systems Handbook” at the following web address:

<http://www.epa.gov/ORD/NRMRL/Pubs/600R03041/600R03041.pdf>

Small Systems Handbook

Small Drinking Water Systems Handbook




Figure 6-4. Cut-away of bag filter

Average % reduction ranged from 40% to 97%. Of course, at higher influent turbidity levels, greater removal can be demonstrated but their service to be a "best" (i.e., MNT) technology level that each head of bag filter can reach regardless of the initial influent quality.

During initial start-up, removal was better and then settled into a fairly steady performance rate until near the end of the bag's life. Flow rate and starting water quality (or lack of) did not seem to be a major factor in that performance. Once a bag begins to fail as 1 to 10 psi differential, the time until the bag must be replaced quickly decreases. High NTU (exceeds 2-3 NTU) indicate the need for multiple filtration barriers in order to not be hampered by having to buy replacement bags every few days. Bag rupture is more likely near the end of the filter run as the pressure differential reaches its maximum. Once a rupture or hole occurs, the treatment barrier is gone with




Figure 6-4. Bag filter showing fabric rupture



Figure 6-7 and 6-8. Bag filters showing discoloration associated with bypass.



Figure 6-5. Bag filter showing rip in seam before pin is inserted.



Figure 6-6. Different configurations of bag filters tested (see Table 6-2)




Figure 6-19. Lag removal of beads vs. membrane surface




Figure 6-20. Number of Beads in Effluent vs. Run Time

samples being taken from the permeate over about four days compared to just one day for the other data points shown in Figure 6-19. After 5332 minutes (approximately 3.64 days) of run time, plastic test beads were still found in the permeate even though influent spiking had occurred over a two-hour period at the beginning of the experiment four days earlier. Removal was 99.9% for the individual experiments, lower than most of the previous experiments. The higher removal rate achieved by the shorter experiments could be the effect of insufficient sample collection time, and suggests that particles may have long residence times in membrane filters but are still capable of ultimately passing through.

Micro Filtration
Various field evaluations have been conducted to assess the operational performance of microfiltration technology and provide information on the removal of physical and biological contaminants under continuous operation. Figure 6-22 shows a typical MF unit. Microfiltration membranes normally have pore sizes 0.1 microns or greater (76). The water flow of the test system ranged between 1.5 and 2.0 gpm. Standardized plastic test beads of 4.5 microns were injected into the raw untreated test water. The reduction of turbidity was 93.3% and the reduction

Small Drinking Water Systems Handbook

It should be noted that although Cryptosporidium is 4-6 microns in size, it can still pass through an otherwise 5 micron test filter by adhering and squeezing through. The stability of Cryptosporidium is demonstrated in Figures 6-21 (a) and (b).




Figure 6-21a. Cryptosporidium oocyst on upper surface of 3 micron pore.




Figure 6-21b. Cryptosporidium oocyst coming through 3 micron pore.






Figure 6-22. Micro Filtration System

***Cryptosporidium* Oocysts**

10



Cryptosporidium oocyst on upper surface of a 3 μ m pore



Cryptosporidium oocyst coming through a 3 μ m pore

Crypto Method 1623 Costs

11

Additional Equipment/Supplies Required for Method 1623	Startup Costs (\$)
Sampling and Sample Processing	\$5,700
ImmunoMagnetic Separation	\$1,600
Chemicals	\$900
Total	\$8,100

Comparison of Bead Removal¹² with Crypto Removal

Beads provide a surrogate that is more difficult to remove than *Cryptosporidium*

Bag Filter	PSL Beads Log Removal	Crypto Log Removal
Strainrite GBP1-2SB	1.3	1.41
3M 523A	2.1	3.4
Strainrite SWT1P + HPM97-CC-2SS	1.92	2.7

Summary of Results

Bag and Cartridge Filter Studies Conducted at the T&E Facility in Cincinnati, Ohio



Disclaimer

**Mention of trade names or
commercial products in this
presentation does not constitute
an endorsement or
recommendation for use**

Small Systems Research

Bag and Cartridge Filtration

- Driver = Long Term 2 Enhanced Surface Water Treatment Rule (LT2)
- LT1 compliance required in January 2005
- 3 µm polystyrene latex bead challenges
 - Surrogate for *Cryptosporidium parvum* oocysts
 - Minimum 2 log removal
- Bag filters and cartridges from several manufacturers in different configurations
- Critical elements: particle removal, effects of turbidity on removal and system longevity
- Challenge with *C. parvum* oocysts

RESEARCH &
DEVELOPMENT

*Building a
scientific
foundation
for sound
environmental
decisions*

Bag, Cartridge, and Ceramic¹⁶ Filtration Research Systems



History of Bag and Cartridge Filter Research at T&E Facility

Years	Filter Configuration	Turbidity	Particle Size Range	Bead Size
1994-1998	Individual Bags/Cartridges	0.5-10 ntu	Mass Loading	None
2000-2002	Individual & In-Series Filters	0-2 ntu	3-7 µm	4.5 µm
2002-2003	Prefilter + 1 µm Filters	0-2 ntu 0-1 ntu	1-5 µm	3 µm
2004	Prefilter + 1 µm + 1 µm Filters	0-1 ntu 0-5 ntu	1-5 µm	3 µm


Comparison of Small System Technology Costs

Technology	Purchase Price	Filter Replacement Cost	Expected Filter Life
Bag Filter (In-Series)	\$4,000	\$10-\$100	hrs/days/wks
Cartridge Filter (In-Series)	\$4,500	\$100-\$600	hrs/days/wks
UF Filter	\$50,000	\$5,000	up to 3 years

5000 Gallon Tank for Turbidity Control Using a Mixture of Mill Creek and Tap Water



Automated Turbidity and Differential ²⁰ Pressure Sensors for Shutdown at Startup, Intermediate, and Terminal Pressure Drop





Bag and Cartridge Filter In-Series Automation Costs

Technology with Datalogging	Pressure and Flow Automation (\$)
Paperless Chart Recorder	\$2,700
Pressure Transducers (3)	\$800
Magneter for Flow Rate	\$3,700
Total	\$7,200

Automated In-Line Particle Counting



Bead Study Injection and Filter Manifold



Bag and Cartridge Filter System²⁴ Pretreatment Options

- Frequency of filter replacement depends on
 - Turbidity levels
 - Nature of turbidity
- Pretreatment may be necessary
 - At turbidities > 1 ntu
 - To reduce filter replacement costs
- Pretreatment options include
 - Settling basins
 - Backwashed pressure sand filters
 - Diatomaceous earth filters
 - Cartridge prefilters
 - Bag prefilters

Optimum System Configurations²⁵ for Crypto Removal

- Depends on:
 - Source water quality
 - Preliminary test results
- Typically:
 - Pretreatment provides gross particulate removal
 - Filters are configured with progressively finer micron ratings with 1 μm absolute filters at the end of the treatment train
 - Cartridge filters (1 μm) are placed after bag filters (1 μm) to protect cartridge filter life and reduce costs

Advantages of Filters In-Series

Filters in-series (two 1 μm filters):

- Guard against short circuiting
- Provide a secondary barrier in case of filter splitting, bursting or rupture

A 5 μm prefilter with two 1 μm filters in-series

- Increases system longevity
- Results in higher initial cost, but lower operating cost

Comparison of Filters In-Series²⁷ and Individual Filters

- Adding filters in-series marginally increases removal
- Removal efficiency based on smallest micron rating

Primary Housing	Secondary Housing	Beads Log Removal
3M 525A	3M 525A	1.18
3M 525A	3M 522A	2.90
3M 522A	3M 522A	2.86
Empty	3M 522A	2.63

General Conclusions from T&E Results

System Configuration	PSL Beads
Bag+Cartridge Filters	>3 Log Removal
Several Bag+Bag Filters (1 micron absolute)	>2.5 Log Removal
Cartridge-Type Filters in Bag Filter Housings	>3 Log Removal



Filters that May Be Eligible for LT2 Crypto Removal Credit

Inlet Turb. (ntu)	Primary Housing	Secondary Housing	Beads (Log Removal)
2.5	Rosedale bag (GLR)	Rosedale bag (GLR)	3.6
2.5	Rosedale bag (PS520)	Rosedale bag (GLR)	3.36
2.5	Rosedale bag (PS520)	Rosedale bag (PS520)	3.49, 3.34
0.13	Strainrite bag (SWT1P2S8T)	Strainrite bag (GBP1-2SB) in Rosedale housing	2.98, 2.84, 2.63
0.2	Strainrite bag (SWT1P2S8T)	Strainrite bag (HPM97-CC-2SS)	2.65, 2.70, 2.65
0.13	Strainrite bag (SWT1P2S8T)	Strainrite bag (HPM99-CGD-2SS)	3.26, 2.55
0.12	Strainrite bag (SWT1P2S8T)	Strainrite bag (HPM99-XCGD-2SS)	2.75, 2.57

Filters that May Be Eligible for LT2 Crypto Removal Credit

Inlet Turb. (ntu)	Primary Housing	Secondary Housing	Beads (Log Removal)
NA	Strainrite bag (HPM99-CGD-2SS)	Strainrite bag (HPM99-XCGD-2SS)	2.74
NA	Strainrite bag (HPM99-XCGD-2SS)	Strainrite bag (HPM99-XCGD-2SS)	2.91, 2.67
2.53	3M 522A in R-P Housing	3M 522A in R-P Housing	2.90, 2.86, 2.71
0.6-1.6	GAF bag (1 µm nominal)	Cycron cartridge (1 µm absolute)	4.56, 3.74, 3.28
0.1-0.2	GAF bag (1 µm nominal)	Harmsco cartridge (1 µm absolute)	3.43, 3.27, 3.03
0.1	Strainrite bag (1 µm nominal)	Harmsco cartridge (1 µm absolute)	3.94, 3.19

Bag and Cartridge Filter System³¹ **Filter Longevity**

Filter life is water quality dependent:

- Coatings from algae or other organic materials may reduce life
- Remaining filter life quickly diminishes after reaching the manufacturer recommended change-out pressures of from 5 to 15 psi
- Rupture typically occurs at differential pressures >25 psi

Examples of Filter Run Times

Inlet Turb. (ntu)	Primary Housing	Secondary Housing	Beads Log Removal	Run Length
~0.2	Strainrite bag (SWT1P2S8T)	Strainrite bag (HPM97-CC-2SS)	2.65	6.4 months*
0.10	Strainrite bag (1 µm nominal)	Harmsco cartridge (1 µm absolute)	3.94	61 days
0.13	Strainrite bag (SWT1P2S8T)	Strainrite bag (GBP1-2SB) in Rosedale housing	2.98	49 days*
0.13	Strainrite bag (SWT1P2S8T)	Strainrite bag (HPM99-CGD-2SS)	3.26	34 days
0.12	Strainrite bag (SWT1P2S8T)	Strainrite bag (HPM99-XCGD-2SS)	2.75	15 days
~0.1	GAF bag (1 µm nominal)	Harmsco cartridge (1 µm absolute)	3.03	13 days

* *Incomplete run*

Examples of Filter Run Times ³³

Inlet Turb. (ntu)	Primary Housing	Secondary Housing	Beads Log Removal	Run Length
0.2 0.15	GAF bag (1 µm nominal)	Harmsco cartridge (1 µm absolute)	3.43 3.27	15 hrs* bags split
2.5	Rosedale bag (GLR)	Rosedale bag (GLR)	3.60	3.6 hrs
2.5	Rosedale bag (PS520)	Rosedale bag (PS520)	3.49	1.4 hrs
2.5	Rosedale bag (PS520)	Rosedale bag (GLR)	3.36	32 min
1.6	GAF bag (1 µm nominal)	Cycron cartridge (1 µm absolute)	3.74	32 min
0.7 0.6	GAF bag (1 µm nominal)	Cycron cartridge (1 µm absolute)	4.56 3.28	34 min 22 min

* *Incomplete run*


Bag and Cartridge Filter System³⁴ **Maintenance Issues**

- Shelf-life impacts filter integrity
- Some filters require preconditioning
- Startup and shutdown filter systems gradually to prevent pressure surges (water hammers) from compromising filter integrity
- Avoid prolonged shutdowns to prevent algae growth

Bag and Cartridge Filter System ³⁵ **Maintenance Issues**

- Only use manufacturer recommended housing/filter combinations
- Use caution during filter installation to protect the fabric from scraps, tears and puncture
- Avoid crimping the bag at the top of the housing

Recent Field Studies in Support of EPA Regions 5 & 10 (MN & WA) ³⁶



U.S. EPA Regions

Summary of Results Field Bag Filter Studies Conducted at Lake Kabetogama, MN



Northern Minnesota

38

➤ Lake resorts

- Open seasonally
- Some year round

➤ Source water

- Surface (lake) water
- Groundwater

➤ Bag filtration

- 3M bags still being used in RP housings
- 3M dropped support of 3M bag filters for drinking water purposes in 1999

Rocky Point Resort Treatment Plant



Typical Treatment Train

Lake water is typically treated as follows:

- Submersible pump in the lake
- Pressure tanks to maintain water pressure
- Prechlorination
- Pressure sand filters
- A single bag filter with 3M 522A bags
- Zenon membrane filters in some locations

Test Apparatus

Test apparatus set up in a trailer at the Rocky Point Resort

- Resort treatment system bypassed to “load” filters for one-week study
- Two bag filter housings in series
- Bead challenge solutions, injection pump, and bead testing manifold
- Analytical equipment

Research Trailer with Bead Study Equipment

42





Bead Study Test Apparatus 43 **3 micron (Crypto-Sized) Polystyrene Latex Beads**



Summary of Lake Water Tests (Turbidity: 2 to 3 ntu)

3M Bag Filter 1	3M Bag Filter 2	Filter Status	Beads Log Removal
525A	522A	Fouled	2.03
525A	522A	Clean	2.34
525A	522A	Intermediately Fouled	2.21
525A	522A	Fouled	2.71

Removal of Housing O-Ring ⁴⁵ Creates Improper Bag Filter Fit



Summary of Lake Water Tests without O-Ring (Turbidity: 1 to 3 ntu)

Strainrite Bag Filter 1	Strainrite Bag Filter 2	Filter Status	Beads Log Removal
SWT1P2S8T	HPM99-XCGD-2SS	Clean	0.35
SWT1P2S8T	HPM99-XCGD-2SS	Fouled	0.44
SWT1P2S8T	HPM97-CC-2SS	Clean	0.20
SWT1P2S8T	HPM97-CC-2SS	Fouled	0.00

Bead Study Filters (Lake Kabetogama Water)

47



Fouled Bead Study Bag



Lake Water Treatment Train at Campground in MN



Summary of Results

50

Bag Filter Studies Conducted at the Paradise Inn/Visitor Center in Mt. Rainier National Park, WA



Bag Filter Bead Study 3 micron (Crypto-Sized) Polystyrene Latex Beads

51



Mt. Rainier National Park, Washington

- **Park Drinking Water Systems**
 - 9 Surface water + 2 Well water
 - 9 Seasonal + 2 Year round

- **Paradise Water Treatment Plant**
 - Paradise Inn
 - Jackson Visitor Center

- **Longmire Water Treatment Plant**
 - National Park Inn
 - Park Service Employee Village

Paradise Inn/Visitor Center Watershed



Water Supply Reservoir (2000 Feet Uphill from Plant)



*Building a
scientific
foundation
for sound
environmental
decisions*

Possible Source of *Cryptosporidium*?



Paradise Inn/Visitor Center Treatment Plant



Paradise Water Treatment Plant

57

- One 50 micron Cartridge Filter
- Two 5 micron Cartridge Filters (in series)
- Four 1 micron Bag Filters (in parallel)
- Post-Chlorination




Clear Well Storage

Pumps lift treated water to an underground storage tank for gravity feed to supply points



Treatment Plant Automation



- Treatment plant well equipped with turbidity meters and automation
- Operated in manual mode due to ongoing system modifications and lightning strikes

Bead Test Apparatus



Bead Test Apparatus

Equipment Configuration:

- Treatment system by-pass line
- Two RP bag filter housings in-series
- Bead challenge solutions
- Injection pump
- Bead test manifold
- Analytical equipment

Bead Study Bag Filters Snowmelt Turbidity (0.12 ntu)



Mt. Rainier National Park, WA Bead Study Test Results

Strainrite Bag Filter 1	Stainrite Bag Filter 2	Filter Status	Beads Log Removal
HPM99-CGD-2SS	HPM99-XCGD-2SS	Clean	2.74
HPM99-XCGD-2SS	HPM99-XCGD-2SS	Clean	2.91
HPM99-XCGD-2SS	HPM99-XCGD-2SS	Clean	2.67
HPM97-CC-2SS	HPM97-CC-2SS	Clean	2.36

Mt. Rainier National Park, WA Bead Study Test Results

3M Bag Filter 1	3M Bag Filter 2	Filter Status	Beads Log Removal
525A	525A	Clean	1.18
525A	522A	Clean	2.90
522A	522A	Clean	2.86
Empty	522A	Clean	2.63

RESEARCH &
DEVELOPMENT

*Building a
scientific
foundation
for sound
environmental
decisions*

Longmire Water Treatment Plant⁶⁵ (Diatomaceous Earth/Bag Filters)



Longmire Water Treatment Plant⁶⁶ (Chlorination/Aboveground Storage)



Chlorinator with
Automated
Chlorine Dosage
and Turbidity
Chart Recorder

Above Ground
Storage Tank
for Treated and
Disinfected
Drinking Water



Bag and Cartridge Filtration under LT1ESWTR (1/14/02)

- Public drinking water systems using
- surface water sources and serving less
- than 10,000 people must comply with
- LT1ESWTR by January of 2005
 - Establishes 2-Log (99%)
Cryptosporidium removal
 - Strengthens combined filter effluent
turbidity performance standards

Bag and Cartridge Filtration under LT2ESWTR (12/10/04)

- Bag and cartridge filters are defined in the regulation as “pressure-driven separation devices that remove particulate matter larger than 1 micron using an engineered, porous filtration media.”
- LT2ESWTR establishes *Cryptosporidium* removal credit based on challenge testing
 - Up to 2.0 log credit for individual filters
 - Potentially higher log credits for filters in series
- Note: Prefilters do not count as filters in series

Bag and Cartridge Filtration ⁶⁹ under LT2ESWTR

- To comply with LT2ESWTR, challenge tests
- must:
 - Test full-scale housings and filters in the same configuration as the proposed plant
 - Test the filters using *Cryptosporidium* or a surrogate with a maximum feed water concentration of the challenge particulate 10,000 times the detection limit of the challenge particulate in the filtrate.
Note: Gross measurements such as turbidity may not be used

Bag and Cartridge Filtration ⁷⁰ under LT2ESWTR

To comply with LT2ESWTR, challenge tests must:

- Be conducted at the manufacturer's maximum design flow rate
- Last for a sufficient duration to reach 100% of the terminal pressure drop

Note: Log Removal Value (LRV) = $\text{LOG}_{10}(\text{C}_f) - \text{LOG}_{10}(\text{C}_p)$
LRV is the minimum LRV observed (≤ 20 filter tests)
LRV is the 10th percentile of the LRV observed (> 20 filter tests)

Bag and Cartridge Filtration ⁷¹ under LT2ESWTR

- Filters must be challenged at three times during
- the filtration cycle:
 - Within two hours of start-up of a new filter
 - Between 45 and 55 percent of the terminal pressure drop
 - After reaching 100 percent of the terminal pressure drop
- A factor of safety is applied to challenge test
- results:
 - 1-log for individual filters
 - Potentially lower for filters operated in series

Bag and Cartridge Filtration ⁷² under LT2ESWTR

If a previously tested filter configuration is modified, a new challenge test must be conducted and submitted to the State

The State may choose to grandfather test results consistent with LT2ESWTR criteria conducted prior to promulgation of LT2ESWTR

Assignment of removal credit does not extend to:

- Other pathogens
- Utilities mandated by the IESWTR or LT1ESWTR (Bin 1 of LT2ESWTR)
- Note: States may extend LT2ESWTR rules to other pathogens or Bin 1 plants

Further Information

LT1 ESWTR:

**[www.epa.gov/fedrgstr/EPA-WATER/
2002/January/Day-14/w409.htm](http://www.epa.gov/fedrgstr/EPA-WATER/2002/January/Day-14/w409.htm)**

LT2 ESWTR:




www.epa.gov/safewater/lt2/index.html

EPA Contact:

**Dan Schmelling (202) 564-5281
schmelling.dan@epa.gov**

Building a scientific foundation for sound environmental decisions

U.S. EPA Arsenic Technology Demonstration Sites



Arsenic Concentrations by County

- >10 µg/L in 10% or more of samples
- >5 µg/L in 10% or more of samples
- >3 µg/L in 10% or more of samples
- >2 µg/L in fewer than 10% of samples
- insufficient data

Site Types:

- G2 media (1 site)
- GPH media (1 site)
- E33 media (3 sites)
- AD-33 media (3 sites)
- AAFS media (1 site)
- IX ion exchange (1 site)
- System modification (1 site)
- CF coagulation/filtration (1 site)

Base Map Source: Walsh, A.H., et al., (U.S. Geological Survey, 2002)

Arsenic Demonstration Program

- October 31, 2001, Administrator announced lowering of arsenic drinking water standard to 10 ppb
- Also announced that “EPA plans to provide \$20 million over next two years for research and development of more cost-effective technologies/training/technical assistance.”
- Focused on small systems (10,000 population or less)

Arsenic Demonstration Funding

- \$20 million targeted for two year program (\$12M EPA; \$8M Congress)
- Full-scale, long-term (1 year) evaluation studies
- Focused on commercially available technologies or engineering approaches

EPA Arsenic Demonstration Program Contact

**Tom Sorg
(513) 569-7370
sorg.thomas@epa.gov**

Arsenic Demonstration Program Objectives

78


- Identify and evaluate new cost-effective technologies
- Demonstrate/verify performance of existing and new commercially available technologies
- Provide technical guidance to small communities, regulators and consulting firms on selection and design of cost-effective systems to meet the 10 ppb arsenic MCL

Arsenic Demonstration Program

- **Project Summary**
 - 43 Project sites
 - 20 States
 - 1 to 4 sites per State

- **Technical Proposals**
 - Round 1 = Funding 12 sites of
17 proposed sites
 - Round 2 = Funding 31 sites of
32 proposed sites


Round 1 - 12 Sites / 9 States



Round 1 Technologies

- 9 Absorption media systems
 - 7 iron media (E33, GFH)
 - 1 Iron-based media (G2)
 - 1 Modified AA (AAFS50)
- 1 Anion exchange system
- 1 Iron removal system
- 1 System Modification
(Iron removal process with Fe addition)

Round 2 - 31 Sites / 19 States



Round 2 Sites

•31 Sites Selected

- Community Water Systems (CWS - 27)
- Non-Transient Non-Community Water Systems (NTNCWS - 4)
- Multi contaminant sites (4)
 - Uranium
 - Gross Alpha
 - Nitrate
- Demonstrates Point-of-Use/Point-of-Entry Approaches

Round 2 Technologies

- Adsorption technologies (60%)
- Oxidation/filtration
- Iron coagulation/filtration
- Ion exchange
- Process modification
- Dissolved air flotation/filtration
- Distillation (POU)
- Reverse Osmosis (POU)

Arsenic Demonstration Program



Checking the impact of treatment on the water chemistry in the distribution system and the water quality at consumers' taps

Arsenic Demonstration Program

Project Outputs (each site)

- Performance Evaluation Reports
 - Six month report
 - One year report
- Summary Report
 - Round 1 studies
 - Round 2 studies

Small Systems Research Government Strategy Advisory Group

- Office of Ground Water Drinking Water (OGWDW)
- Office of Science and Policy (OSP)
- EPA Regions
- American Indian Environmental Office
- Office of Research and Development (ORD)

Small Systems Research Non-Government Strategy Advisory Group

- National Rural Water Association
- Rural Community Assistance Programs
- American Water Works Association
- AWWA Research Foundation
- Water Reuse Federation
- Water Environment Research Foundation
- Rural Utilities Service (USDA)
- National Drinking Water Clearing House
- Water Quality Association
- Electric Power Research Institute
- Private vendors/consultants

Small Systems Research- Future Issues

- Radionuclides
 - Uranium
 - Radium
 - Radon
- Perchlorate
- MTBE
- LT2/Stage 2 DBP Rules
- Water Reuse
- POE/POU
- Remote Monitoring Control & Reporting

Thank You

Small Drinking Water Systems

**Craig Patterson (513) 487-2805
patterson.craig@epa.gov**

- **LT2 ESWTR**
- **Dan Schmelling (202) 564-5281**
 - **schmelling.dan@epa.gov**

Arsenic

**Tom Sorg (513) 569-7370
sorg.thomas@epa.gov**

Website Information

Small Systems:

www.epa.gov/ORD/NRMRL/wswrd/smallsys2.htm

Upload “Small Drinking Water Systems Handbook”:

www.epa.gov/ORD/NRMRL/Pubs/600R03041/600R03041.pdf

LT1 ESWTR:

[www.epa.gov/fedrgstr/EPA-WATER/
2002/January/Day-14/w409.htm](http://www.epa.gov/fedrgstr/EPA-WATER/2002/January/Day-14/w409.htm)

LT2 ESWTR:

www.epa.gov/safewater/lt2/index.html

Arsenic:

www.epa.gov/ORD/NRMRL/arsenic/